

**UNITED STATES DISTRICT COURT
NORTHERN DISTRICT OF NEW YORK**

LAWRENCE K. BAERMAN
Clerk

JOHN M. DOMURAD
Chief Deputy

DAN MCALLISTER
Chief Deputy



James M. Hanley Federal Building
P.O. Box 7367, 100 S. Clinton St.
Syracuse, New York 13261-7367
(315) 234-8500

MEMORANDUM

TO: Prospective Data Wiring Contractors

FROM: Sunday Heuser, Contracting Officer/Procurement Admin.

DATE: June 4, 2013

SUBJECT: Clarification Response #3 - Floorboxes and Poke Through Devices - USDC-#5-17-2013

Clarification: Previous correspondence noted that all floor boxes were converted to poke throughs. This however is not the case.

Answer:

All floor boxes in the Judge's private office are now poke-throughs. Floor boxes in the courtroom remain as floor boxes.

If you would like details on the poke throughs and floor boxes that are being used, please let me know.

If you have any other questions, please feel free to contact me.