

UNITED STATES DISTRICT COURT  
NORTHERN DISTRICT OF NEW YORK



LAWRENCE K. BAERMAN  
Clerk

JOHN M. DOMURAD  
Chief Deputy

DAN MCALLISTER  
Chief Deputy

James M. Hanley Federal Building  
P.O. Box 7367, 100 S. Clinton St.  
Syracuse, New York 13261-7367  
(315) 234-8500

MEMORANDUM

TO: Prospective Audio Visual Contractors  
FROM: Sunday Heuser, Contracting Officer/Procurement Admin.  
DATE: July 22, 2013  
SUBJECT: System Questions Response #4 for 11<sup>th</sup> Floor Courtroom Audio Visual RFQ - USDC-SYRCR#(8)-06-14-2013

The following questions were presented to the Court in regards to the AV system:

**Proposed Question:** Should remote translation be included in the response to this RFQ?

**Answer:** Yes

\*\*\*\*\*

**Proposed Question:** Will you consider a substitution of Listen Technologies infrared listening/translation system to the current Sennheiser system?

**Answer:** Yes, substitutions will be accepted. Please note appropriate substitution equipment on all documentation submitted to the Court as your response.

\*\*\*\*\*

**Proposed Question:** Please confirm that we should quote the ALS system (either mfr) to comply with 2010 changes to the ADA which require that two receivers be hearing-aid compatible. To comply, we need to provide (2) lanyard receivers with neck loops in addition to or in place of the two specified stethoscope receivers.

**Answer:** Yes, we should comply with the ADA requirements. Please provide the (2) additional lanyard receivers along with the stethoscope receivers so they can be used with any hearing aid devices by the end user.

